


Danish experiences in district heating on renewable energy sources



- Unabhängiges Ingenieurbüro
- Gründungsjahr: 1983
- Etwa 30 Angestellte
- Abteilungen in:
 - Skørping
 - Aarhus
 - Kopenhagen



Morten Hofmeister
Max Guddat
PlanEnergi
Denmark
mh@planenergi.dk

- Arbeitsbereiche:
 - Fernwärme
 - Solarthermie
 - Saisonwärmespeicher
 - Wärmepumpen
 - Energieplanung
 - Biogas
 - Umweltverträglichkeits-studien für Windmühlen

Planning

Danish experiences in district heating on renewable energy sources



EKI-Fachforum, New Energy in Husum 18 March 2016



Co-funded by the Intelligent Energy Europe
Programme of the European Union

Morten Hofmeister & Max Guddat



Multiple advantages (comfort, environment)

Competitive price for consumers – society economy

Facilitates solving of e.g. waste problem

An enabling energy infrastructure

Public participation and acceptance

- Public acceptance ensured by local initiative
- Advantages for all actors – “what’s in it for me” (can, will, want)
- Perceive district heating as energy infrastructure – enabling and facilitating utilisation of energy resources
- Requires appropriate framework conditions – providing incentives to the actors

Danish Heat Planning – before the planning

Today, municipalities are the main authority on heat planning and can own a heat supply utility, and thus be involved in operation. But originally, heating of homes was solely an individual task

- In the beginning of the 1900s the surplus heat from the power plants was utilised in e.g. hospitals and other large buildings
- In the 1920s and 1930s, centralised collective heating emerged in larger new-build areas of houses
- In the 1950s a largescale establishment of district heating plants was initiated – 5 new plants per year.
- The peak was in the 1960s, with 45 new plants in 1964
- The development of district heating was on private initiative – consumers organised themselves and established a district heating plant
- Only in a few cases, municipalities was behind the establishment of a district heating plant
- The primary role of the municipalities was to provide guarantees for loans
- District heating started without national political objectives
- Private initiatives, consumers organised themselves (consumer owned utilities)

– Steps

- Municipalities to map the existing (and estimate the future) heat demand, the applied heating methods and energy usage
- Interaction between the municipalities and the counties (regional heat plans)
- Oil crises in the 1970s initiated energy policy
- Heat Supply Act in 1979 – detailed planning
- Security of energy supply, reduce oil imports
- No more "free choice" for consumers

– The contents of the plans

- Identify in which areas the different heat supply technologies had priority
- The location of future heat production plants and pipelines

Danish Heat Planning – the 1980s

- Environment
- CHP
- New technologies
 - Small CHP, biomass and waste
- Mandatory connection
 - 1982, still in force, but not widely applied
 - The municipalities could secure the investments made by the utilities as regards heat density
- Ban against electrical heating
- Taxes
 - Biomass and biogas was exempt from taxes
 - High level of taxes also in times of low fuel prices to keep incentive for energy conservation


Danish Heat Planning – the 1990s

- After successful implementation in the 1980s
 - Objective was to simplify and decentralise the decision process for establishment of new DH plants
 - Project based planning scheme
 - Reduce CO2-emissions and secure investments in natural gas infrastructure
 - Detailed regulation facilitated implementation
- Phases of regulation (issued by the state to municipalities)
 - 1 phase (1990-1994): Large coal-fired district heating plants with access to natural gas, to be converted. Introduction of waste incineration
 - 2 phase (1994-1996): Remaining coal-fired district heating plants with access to natural gas to be converted. Biomass (straw, wood chips)
 - 3 phase (1996-1998): Small natural gas fired district heating plants converted to CHP. Remaining small plants converted to biomass

DENMARK's PROGRESS OVER THE PAST TWO DECADES



Centralized System of the mid 1980's




More Decentralized System of Today

Danish Heat Planning – Summary

- 1980's: Security of supply
 - After the oil crisis, substituting oil with natural gas (own production)
 - Zoning of geographical areas – individual natural gas and district heating (in total four types of zones)
 - Process driven by the energy utilities
 - The municipalities had an active role in the planning process
- Since approx. 2007: **Climate agenda**
 - New round of heat planing, new employees in the municipalities
 - Project-scheme
 - The municipalities has a role again (after some years without heat planning, after the success in the 1980s and 1990s).
 - Municipal guarantee
 - Resources from the municipalities: hours (no investments)
 - Now more focus on the differentiated role of the municipalities; authority (taxes) and operation (fees for heat supply)
- The development is driven by political targets (security of energy supply, climate, etc.)
 - Value of the political targets should be reflected in the regulatory framework (e.g. taxes)
- The planning hierarchy in the 1980s:
 - The state
 - The counties
 - The municipalities
- In 1990: The municipalities became solely responsible for the heat planning, given some overall regulations by the Minister
- Regulatory framework is somewhat outdated
- Today: The municipalities may wish for a more active national planning, enabling the municipalities to obtain the overall political targets

Danish Heat Planning – Reflections and the future

- Broad scope and long time horizon is crucial for district energy
- Public acceptance – and adoption, i.e. local initiative is crucial
- “Organic growth”, supported by national and regional planning
- The current trend is strategic energy planning – a broader scope in terms of both topics and geographical areas
- The subject of public participation – or acceptance – is crucial for the success of collective systems
 - Unless participation is made mandatory (which was the case in Denmark).
 - A crucial argument for introducing collective systems (including heat systems) is that it is an advantage to both the individual and the society.
 - You need organizations to organize the investments etc., i.e. linking the individual and the society (in this case district heating companies).
- Planning of district heating should be made in coordination with other energy planning, in particular electricity
 - The large – and increasing – amount of wind power in the Danish energy system can only be utilized effectively if electricity is used in heat pumps, which also utilize waste heat from industry etc.
 - District heating does not only concern heat supply and supply of hot tap water – district heating is a crucial part of the energy infrastructure, enabling utilization of fluctuating renewable energy sources.



Danish Heat Planning –current status


- May 2014: Analyses issued by the Danish Energy Agency, www.ens.dk
- Share of solar and wind in the nordic countries and Germany is assessed to be 25% by 2025 and 40% by 2050
- Small DH: natural gas based CHP substituted by solar thermal and heat pumps
- Medium-sized DH: Increased CHP based on waste and biomass, substituting natural gas
- Large DH (see figure): Increase of CHP until 2035, then surplus heat and limitation in biomass. Waste on boilers.

The Role of the Municipalities 1/2

- Role as heat authority
 - Planning authority – responsible for planning the heat supply in the municipality together with utilities and other relevant actors
 - Approving authority – approving specific projects in the municipality, ensure implementation
 - The municipality can take initiative on specific projects
 - Responsible for coordination with other municipal planning
- Role as owner and operator of district heating utilities
 - Approx. 55 district heating utilities (of more than 400) are municipal, but delivering more than 60 % of the district heating.
 - Close cooperation – often representatives from the municipality in the board of the utility
- Role as authority
- Role as owner and operator

District heating price

– According to ownership; commercial, municipal or consumer-owned



- Challenge of capacity and competences in the municipalities
- The municipalities has a large responsibility
- Strategic energy planning address this gap




Community Energy Planning

- Community energy planning
 - Strategic Energy Planning, in Denmark not including transport. Main focus is on district heating and electricity.
 - In Denmark: The municipality is the key authority for heat plans.
 - Heat Supply Act – role of municipality. Role of the state (Danish Energy Agency).
 - Taxes plays an important role – can be counterproductive related to the energy and climate policies. Hence, the state plays an important role.
 - Regional level – no formal responsibility. Facilitates coordination between municipalities (own initiative, not regulated role). Motivation – generate employment.
- Roles of different actors changing over time
- Outdated regulation is counterproductive for obtaining new political objectives

- Acknowledge district energy as key energy infrastructure
- Create framework for establishment of local organisations investing in and operating district energy
- It is a common challenge – create the framework and focus on local initiative


District heating price

– Heat price for standard house of 130 m² and yearly heat consumption of 18,1 MWh




District heating tariffs

– Income 2014/2015 split on variable and fixed payments and motivation tariff




District heating price – According to primary fuel type



District heating is competitive (in most cases)


Heat prices incl. VAT 2013
1.000 DKK and number of plants in %



130 m² house, 18.1 MWh/year
Depreciation not included

Competitiveness of district heating based on different fuels





Varmepriser inkl. moms 2013




130 m² house, 18.1 MWh/year

Depreciation not included

Types of energy systems




Change for renewable energy - options




District heating with renewables in Denmark

Combination – CHP, solar thermal and heat pump



District Heating and CHP - The Implications of Electricity Production

- Subsidy for electricity production (1992)
 - Electricity production – not always
 - In 2003; change in the subsidy for electricity production for CHP-plants
 - Avoid economic losses for society, only producing electricity when there is a demand (not exporting below production costs)
 - Flexible, storages
 - Denmark has 16 central CHP – plants which originally was only power plants
 - Denmark has 415 decentral plants, of which 285 are CHP and 130 are heat-only plants. All decentral plants was originally heat-only plants
 - Main purpose of the decentral plants is heat production
- Observe the system advantages and disadvantages
 - Flexibility is key
 - Central and decentral plants



Interaction between the German electricity system and the Danish district heating system

Challenges for the German electricity system

- Due to imbalances caused by wind power and bottlenecks in the German electricity system
- Northern electricity markets are more efficient

Export from Denmark to Germany of regulating capacity – down regulation

- "Special regulation" – does not affect the domestic pricing on the regulation market
- Price is defined by the bidder, including profit

Options for down-regulation

- Plants, reduce power production
- Electric boilers, increase power consumption
- Wind turbines, reduce power production

Fjernvarmen kan tjene på
specialregulering
Der er store penge i at konvertere el til varme. Potentialet for
fjernvarmeverkerner er stort, viser oversigten fra 2015.

ELREGULERING Danmark har velfungerende markeder for el. Det er blandtandet medvirkende til, at Danmark kan integrere så meget indkraft på en økonomisk effektiv måde, som tiltrædet er. Reguleringsmarkedet, som er det markeds, hvor Energinet dækker udbalance, er udbyder, at den sidst aktiverede aktør i en given tids bestemmer den pris, en alle aktører afregnes til. Derfor er den optimale børsstrategi for aktørerne at melde deres kapacitet ind i markedet til deres marginale omkostninger.

Større tykke problemer med vind-ubalance
Det seneste års tid har det nordtyske system har svært ved at håndtere ubalancer som følge af vindurder. Der er store fælleskader mellem Nord- og Sydtyskland, hvorfor man i mange timer ikke kan transportere vind fra Nordtyskland til de store forbrugscentre længere sydpå. Desuden er de tyske elmarkeder ikke så effektive som de nordiske. Derfor har Tyskland fået et omkringliggende lande om hjælp, når Nordtyskland oplever en stærre indkraftproduktion end prognosticeret. Danmark hjælper med nedreguleringen.

Nedregulering kan leveres på følgende måder:

- Værker, som kan "være ned", dvs. producere mindre strøm, end de har medtalt ind i markedet.
- Elpatroner, som omstætter strømtilværelse.
- Vindmøller, som standses.


Når der behov for nedregulering, er det ofte, når elprisen i forvejen er faldet ned, og videnproduceren sattes. Dog vil alle priser for specialregulering i en given tids være mindre end nedreguleringens pris.

Reguleret aktivering i 2015
Almindelig og specialop- og nedregulering i Vestjylland i 2015:

Opregulering	Mængde	Gennemsnitlig pris
Nedregulering	199.63 M Wh	199 kE/kWh
Specialopregulering	16.03 M Wh	249 kE/kWh
Specialedregulering	33.48 M Wh	
	400.83 M Wh	

2015 var den gennemsnitlige spartid i Vestjylland 1.702 kWh per elkunde og prisen 200.000 kWh nedregulering og 1.500 kWh specialedregulering og 200.000 kWh specialopregulering. Denne pris er ikke inkluderet i elkraftselskabets omkostninger. Specialedregulering er betydeligt dyrere end normalt. Den har været 2.000 kWh almindelig nedregulering producerer mere end forventet. Det har været 2.000 kWh almindelig nedregulering som almindelig nedregulering.

District heating from 1G to 4G



Source: Lund H., et al., 4th generation District Heating (4GDH), Energy 2014, <http://dx.doi.org/10.1016/j.energy.2014.02.089>

www.4dh.dk

DH's role in future sustainable energy systems requires meeting the challenges:

1. Low temperature DH to old and new buildings
2. Distribute heat with low heat losses
3. Recycle heat from low temperature sources and integrate renewables
4. Integrated part of smart energy systems
5. Suitable planning, cost and motivation structures

Examples



Small, modular district heating with renewables in Denmark

See brochure from FleksEnergi at: <http://fleksenergi.dk/2015/05/22/nyhed-2/>

The World's Third Largest Solar Thermal Plant

In 2013, Dronninglund District Heating Plant invested in a renewable energy system to phase out 50 % of their yearly consumption of fossil fuel - a decision that made this Danish district heating plant one of the world's largest solar thermal plants.

Surrounded by tall trees, on top of a former gravel pit, you find Dronninglund District Heating which is one of the world's leading district heating solar power plants. From a distance, you cannot distinguish the enormous pit heating water storage containing 60,000 m³ of water, or the technical building with pipes, pumps, and heat exchangers. All you see is a fabric roof consisting nothing less than 3,573 m² of 800 solar panels divided into fields. Individually connected to a heat exchanger in the technical building. Each row has 21 solar collectors connected in sequence and mounted on galvanized steel profiles processed into the ground.

- The plant supplies 1,350 households with heat, and today 50 % of the yearly production is provided by our new solar thermal system, says Plant Manager of Dronninglund District Heating, Johan Frey.

The Benefits of Solar Panel Energy
During summer, the solar thermal plant produces much more heat than the town of Dronninglund consumes, and the excess heat is used to heat the water storage thereby creating a heat storage for the less warm autumn and winter periods. The plant runs unattended most of the time, however, Johan Frey inspects the technical building three times a week to ensure the machinery is performing well. According to him, the system is easy to operate and has low operating costs. He is very content with their transition to green energy.

- We have a trouble-free operation and contribute to a cleaner environment by replacing fossil fuels with inexhaustible, green power supply. Because we know our fuel price the next 20 years, the heating price for a standard household has been reduced by 265 Euros annually, he says.

Cooperation Within the Network
The implementation of Dronninglund solar thermal plant is an excellent example of the collaboration between FleksEnergi members. In the process of constructing the solar thermal plant, several member companies have provided important products and consultancy. Aitom Sunergy, a world-leading solar thermal company, has provided the solar thermal collectors. Sales Executive Knud Erik Nielsen sees great potential in the network:

- We benefit from being part of the FleksEnergi network. It gives us the possibility to share knowledge with other complementary companies. Being on the cutting edge of our technology requires a holistic approach to problem solving and innovation. And it is also our experience that collaborating with other members on projects helps us bring great solutions to our customers.

One District Heating Plant – Several Energy Sources

Thisted District Heating Plant is an innovative heating plant that uses several renewable energy sources. In the process, they welcome businesses to cooperate in testing new technologies.

Implementing Green District Heating

District Heating Cluster in North Denmark

fleksenergi

Danish experiences in district heating on renewable energy sources




EKI-Fachforum, New Energy in Husum 18 March 2016



Co-funded by the Intelligent Energy Europe Programme of the European Union

Morten Hofmeister & Max Guddat



Heating Plant

Gets the Most Efficient Bio-Fuel Boiler in the World


Hjørring District Heating's new multi bio-fuel boiler is probably the most efficient in the world. The plant's investment in green energy has lowered the local heating price significantly.

Aars District Heating Links Towns Together

Both the environment and the consumers enjoy the fact that several minor district heating companies in North Denmark are now connected in an extraordinary transmission network.

District heating with renewables in Denmark

Types of renewables, land area requirement



Parameters to consider:

- Investment
- O&M
- Fuel price
- Area (factor 25 solar thermal and biomass)
- Other...

Solar district heating





Figure 3: Overview of the installed Danish solar district heating systems in operation by September 2014

Reasons for this development:

- Energy tax on natural gas
- Restrictions on choice of fuel (natural gas)
- "Energy saving" first year production
- Municipal loan guarantees
- Exchange of experience and information in the Danish District Heating Association
- Reliable technology with long life-time

Solar thermal plants in Denmark

Area and number of plants (accumulated), in operation and planned



Solar thermal in other European countries, see www.solar-district-heating.eu




Figure 41: Solar district heating and cooling in Europe – capacities installed and No. of systems by end of 2014
(Data source: Jan-Olof Dalenbäck - Chalmers University of Technology, SE)

Facilitation of the development of solar district heating




- 2007: Solar thermal strategy, Danish Energy Agency and Energinet.dk
- 2011: Action plan, initiated by the Danish Energy Agency

Key points of the action plan:

1. Research, development and demonstration of system integration, control optimisation and development of seasonal heat storages
2. (Decentralised solar thermal panels supplying to district heating network)
3. Optimisation of components
4. Information and education (calculation tools, guidelines, training courses, quality assurance)


Development perspectives for solar thermal

- More suppliers
 - Arcon-Sunmark, Viessmann, KBB, Clipsol, Savo Solar, Greenonetech
 - More development and competition
- Solar thermal and biomass
 - Feasible in combination with wood chips and straw (including "energy saving" subsidy)
- Solar thermal with storages
 - Up to 80 % of yearly heat demand
- Hybrid systems
 - Combinations with other technologies
- Solar thermal for large cities
 - Graz; 265.000 inh., 450.000 m² solar panels, 1,8 million m³ storage
- Solar with higher temperatures
 - For industry and district heating
 - E.g. CSP (concentrated solar power and ORC (organic rankine cycle)



District heating with renewables in Denmark

Brædstrup




District heating with renewables in Denmark

Example; Føns



- 2*200 kW biomass boilers
- 40 consumers
- Started operation 2015




District heating with renewables in Denmark

Combinations – solar thermal and seasonal heat storages

Coverage of solar thermal:

- Approximately 20 % of yearly heat demand
- Higher with seasonal heat storages
 - Pit Thermal Energy Storage (PTES)
 - Dronninglund, **Marstal**, Gram
 - Borehole Thermal Energy Storage (BTES)
 - **Brædstrup**



Heat pumps in DH




Output:

Drehbuch

Inspirationskatalog


Arbeitsblatt für interessierte Werke (Excel)



- Introduction
 - Why consider heat pumps?
 - How could heat pumps fit in the current district heating supply? Short and long term
- Initial assessment
 - Which heat sources are available? Cf. the types in the inspiration catalogue
 - Choice of heat pumps, plant concepts, system solutions
 - Approvals (authorities)
- Economy
 - Taxes, PSO
 - Connection to electricity grid, fees
 - Possibilities for income from the electricity market
- Organisation
 - Contracts (e.g. with supplier of surplus heat)
 - Tender and choice of heat pump supplier
 - Performance test
- Conclusions
 - Perspectives

District heating with renewables in Denmark

Combination – CHP, solar thermal and heat pump (ground water) – Rye (DK)




- Reduce natural gas dependency
- Natural gas, electricity production
- Solar thermal (free fuel)
- Heat from groundwater (flexible electricity consumption)

District heating with renewables in Denmark

Combination – CHP, solar thermal and heat pump (ground water) – Rye (DK)


- Das Werk:
 - 360 Verbraucher
 - 9.325 MWh/a
 - Erdgasmotoren
($2 \times 1 \text{ MW}_{\text{th}}$)
 - Erdgaskessel ($3,2 \text{ MW}_{\text{th}}$)
 - 2.400 m^2 Solarthermie



Wirtschaftlichkeit Rye

Wärmepumpe Rye - 2.000 kW	
Investition	1.370.000 €
Jährlicher Betrieb	3.000 Stunden
Jährliche Wärmeerzeugung	6.000 MWh
Ersparnis pr. MWh	26 €/MWh
Jährliche Ersparnis	150.000 €
Amortisationsdauer	8,9 Jahre
Interner Zinsfuß 15 Jahre	7%

Großwärmepumpen, Status 2015



PlanEnergi-Projekte mit Baubeginn 2016

- Broager
 - Klein-Mittel, Erdgas-KWK mit Solarthermie
 - Grundwasser
- Ans
 - Klein-Mittel, Erdgas-KWK + Kessel
 - Seewasser
- Dronninglund
 - Klein-Mittel, Erdgas-KWK, Bioöl-Kessel, Grossflächen-Solarthermie + Erdbeckenspeicher
 - Grundwasser
- Rødkærnsbro
 - Klein, Erdgas-KWK
 - Abwärme von Meierei
- Farstrup-Kølby
 - Klein, Erdgas-KWK + Kessel
 - Grundwasser
- Præstø
 - Klein-Mittel, Erdgas-KWK mit Pellet-Kessel
 - Grundwasser


Hadsund Bys Fjernvarmeværk a.m.b.a.

Grundlagenanalyse zu Masterplan

Redner: Max Guddat, PlanEnergi

Agenda: Beschlussgrunde Hadsund

- Vorraussetzungen & Referenz-Scenario
- Teil 1: Versorgung von Erdgas-Großverbraucher
- Teil 2: Abwärme
- Teil 3: Erweiterung der Solathermie
- Teil 4: WKA zur Wärmeerzeugung
- Sensitivitätsanalysen
- Konklusion



Das Werk

- 1962 etabliert, 315 Verbraucher (Öl-Kessel)
 - 1985: 1.000 Verbraucher
- 2016: 2.000 Verbraucher, Transmissionsleitungen zu benachbarten Wärmesystemen, Hackschnitzel, Solarthermie
- Jahreswärmeverbrauch: 70.000 MWh/a ab Werk im „Normaljahr“

Vorgehensweise

- Berechnungsgrundlagen: Schätzungen, Erfahrungswerte und bekannte lokalspezifische Voraussetzungen.
 - Strombörsenpreise 2014, Abgaben 2015
 - Sensitivitätsanalysen von u.a. Hackschnitzelpreis & Abgabenänderungen
 - Angaben von Ist-Werten von Großverbrauchern, potenziellen Abwärmequellen und Lieferanten
- Techno-ökonomisch optimierte Modellierung in energyPRO
- Betriebswirtschaftliche Analyse in Excel anhand von energyPRO-Output

Der Referenz-Betrieb

- Ist-Betrieb: Hauptsächlich Hackschnitzel, Solarthermie mit Inbetriebnahme primo 2016
- **Wärmezentrale Fabriksvej:**
 - 2x7 MW_{th}, Hackschnitzelkessel mit Wärmerückgewinnung
 - 4.595 m³ Wärmespeicher
- **Solarthermie:**
 - 20.516 m², ca. 480 kWh/m²
- **Ölzentralen (Spitzenlast & Reserve):**
 - 2x6 MW_{th}, 1x2,25 MW_{th}, 2x2 MW_{th}
- **Wärmespeicher im Netz:**
 - 100 m³, im Wärmebedarf enthalten



Brennstoffpreise, Abgaben & IWI

- 2015-Ist-Preise
 - Hackschnitzel:
 - Brennstoff: 22,2 €/MWh_{FW Ab Werk}
 - NO_x-Abgabe: 0,32 €/GJ_{Brennstoff}
 - IWI: 2 €/MWh_{th Ab Anlage}
 - Heizöl:
 - Brennstoff: 65 €/MWh_{FW Ab Werk}
 - Energie-Abgabe: 0,299 €/kg_{Brennstoff}
CO₂: 0,0726 €/ kg_{Brennstoff}
 - NO_x: 0,020 €/kg_{Brennstoff}
 - IWI: 8 €/MWh_{FW Ab Anlage}
 - Solarthermie:
 - IWI: 0,801 €/MWh_{FW Ab Anlage}


Wärmebedarf, Gradtagmethode

Skyggegraddøgn for NORDJYLLAND sammenholdt med HELE LANDET

År	Måned	NORDJYLLAND			HELE LANDET		
		Skygge-graddøgn	Skygge-graddøgn, EMD-normal	Afgigels e fra EMD-normal	Skygge-graddøgn	Skygge-graddøgn, EMD-normal	Afgigels e fra EMD-normal
		(Antal graddøgn)	(Antal graddøgn)	(%)	(Antal graddøgn)	(Antal graddøgn)	(%)
2014	1	519,3	505,9	2,6	521	492,6	5,8
2014	2	397,6	440,9	-9,8	373,2	431,4	-13,5
2014	3	376,5	458,3	-17,8	356,8	444,8	-19,8
2014	4	286,3	342,7	-16,5	256,5	329	-22
2014	5	179,5	210,8	-14,8	168,8	202,9	-16,8
2014	6	74,9	118,8	-37	68,8	108,5	-36,6
2014	7	13,8	62,2	-77,8	11,7	52,5	-77,7
2014	8	70,2	67,9	3,4	57,7	52,7	9,5
2014	9	93,3	155,6	-40	66,1	133,4	-50,4
2014	10	190,6	279,8	-31,9	161,1	258	-37,6



Bei Erschließung neuer Versorgungsgebiete: Wärmeatlas



Tabel 11. Beregnede nuværende enhedsforbrug i de analyserede bygningstyper og byggeperioder jf. registreringer af konstruktionernes nuværende termiske egenskaber i forbindelse med energimærking.

KWh/m ² pr. år	Før 1890	1890-1930	1931-1950	1951-1960	1961-1972	1973-1978	1979-1998	1999-2006	Efter 2006
Stuehus	184,3	171,4	161,8	151,2	136,2	116,9	100,3	81,0	66,6
Parcelhus	170,3	164,7	164,1	154,9	134,3	119,8	105,4	83,9	67,3
Rækkekædehus	158,2	157,7	149,3	142,8	119,9	112,6	96,8	81,5	66,4
Etagebolig	151,1	153,9	157,0	148,0	132,3	121,0	108,5	84,0	60,7
Kollegium	137,9	149,2	136,4	145,7	130,6	139,1	131,7	84,0	58,2
Degrinstitution	164,1	161,9	152,3	140,2	143,2	136,9	116,0	94,1	63,3
And. højresbolig	161,1	165,7	158,4	161,4	135,8	132,7	101,0	80,4	66,6
Kontor/handel	129,8	125,2	129,0	126,7	117,5	120,0	103,3	89,6	82,8
Hotel og service	172,0	166,5	152,4	160,9	157,2	172,0	141,8	122,6	121,1
And. hand/serv.	82,7	119,0	123,6	107,4	125,7	139,9	116,6	102,7	96,0
Kulturbygning	166,0	156,1	156,5	139,2	125,8	118,4	131,2	105,1	96,6
Undervisning	126,2	136,3	141,0	133,8	135,1	145,6	115,1	100,0	86,2
Sygehus	195,3	178,4	173,2	177,3	153,8	156,5	149,6	138,6	129,7
Daginstitution	170,7	181,7	173,8	171,6	172,8	166,1	143,5	133,9	115,9
And. institution	177,9	175,8	178,2	201,7	179,1	169,1	139,4	135,3	117,6
Sommerhus	205,8	162,5	150,0	176,7	154,6	126,6	134,8	90,8	73,1
Feriebygning	139,6	150,5	172,4	112,1	137,9	122,1	125,4	68,9	35,9
Sportsanlæg	198,1	206,8	187,8	173,4	165,3	163,1	155,0	138,3	119,3
And. fritidsbygn.	163,4	132,0	149,7	154,7	129,8	129,0	115,0	98,6	76,8

1) Det beregnede enhedsforbrug for bygninger til anden handel og service, opført i perioden før 1890, er usædvanlig lavt. Data er forkundet med stor usikkerhed da der kun findes meget få bygninger fra denne periode i databasen fra EMO ordningen. Der er meget få bygninger registreret i BBR registeret for denne periode, og usikkerhet i denne periode vil derfor kun have marginal indflydelse på de samlede resultater.

POTENTIELLE VARMEBESPARELSER
VED LØBENDE BYGNINGSRENOVERINGER
FREM TIL 2050


SBI 2014:01



SBI 2014:01: Potentielle Varmebesparelser
ved løbende Bygningsrenoveringer frem til
2050, p. 26

Biobrennstoffe: Potenzialerfassung

- Potenzialerfassung in kommunalem Projekt
 - Methode entwickelt durch Aarhus Universität



Figur 16: Husdyrbrug i kommunerne.

Revideret 4. december 2012 - afgrødedata for 2011, dyrehold GHI 2011 - halm og udbytter mv. ikke opdateret - ark regionale data							
Udnyttelser- Noder- ende Scenario	Tilag	Aalborg		195.145 indb			
		Potentiale	Scenario Hestar	Udnyttet	Scenario RJ	Udnyttet Pr.indb. GJ	
74% 25%	4. Energialgrøder af enslet med energialgrøder og udtagne arealer på hejgrund anvendes til energialgrøder (ex raps og majsplantninger) af arealer med kom til modenhed anvendes til energialgrøder	936	234	694	0,04	0,11	0,2
0% 15%		38.765	5.815	0	1,12	0,00	5,7
70% 100%	2. Olivproduktion af rapssædet udnyttes til energi	4.208	4.208	2.945	0,15	0,11	0,8
	3. Halm Reduceret kompasel Foder og støtelse af halmproduktion fra kom, der ikke anvendes til foder og støtelse udnyttes til energi	32.950 12.299					
0% 80%		20.650	16.520	0	0,78	0,00	4,0
13% 80%		4.208	3.366	526	0,14	0,02	0,7
	4. Brændsel fra skove, hegning og have Skovareal antages anvendt til tømmer, mens en typisk udnyttelse på 1,5 tons t pr. ha er anbragt til energi. I scenarioet øges fyndighedsugsten til 2,25 tons t pr. ha anvendt til energi. En tilsvarende energimængde antages på landsplan udnyttet fra mindre skove, hegning og have	8.813	8.813	8.813	0,32	0,21	1,6
100% 100%		104.489			0,35	0,35	1,8
	Biogas						
	5. Græs af lavbundsareal med græs eller ekstensiv afdrygger hæstes til biogas	4.343	3.257	0	0,14	0,00	0,7
0% 75%							
	6. Husdyrgedning af husdyrgedning på stald anvendes til biogas	1000 m3 metan					
6% 75%		19.051	14.288	1.182	0,51	0,04	2,6
Beregningsfaktorer							
Tørstof pr ha	Procent olie GJ pr ton	PJ pr ha					
10	16	0.00016					
12	16	0.000192					
3,1	33%	35	0.000036				
2,8	17	0.000048					
2,4	17	0.000041					
2,3	16	0.000036					
1,5	16	0.000024					
Tørstof pr ha	m3 methan/kg	PJ/mill tørstof					
3,5	0,35	0,036	0,000041				
5,28	0,036	0,000036					

energyPRO - Grafisches Interface

energyPRO 4.3 - 0 Hadsund Reference (Beregnet)

Filer energyPRO opstætning Projekt opstætning Værktøjer vindue Hjælp

Inddata

- Samlet solindstråling, DRY, zone 1, Nordjylland
- Fremlobstemperatur 2014
- Returtemperatur 2014
- Temp Solfanger Frem
- Tidsserie funktioner
- Indekser
- Lokaliteter
- Hadsund Varmevark inkl. VSV
- Solfangerfelt
- Forbindelser
- Forbindelse
- Brændsler
- Flis
- Olie
- Behov
- Varmebehov Hadsund + VSV
- Energikonverteringenheder
- Fliskedel 1
- Fliskedel 2
- Solfanger
- Afbællsing
- Oliedel 1 Hornbech
- Oliedel 2 Hornbech
- Oliedel 3 Hedepark
- Oliedel 4 Transbjerholt
- Oliedel 5 Transbjerholt
- Lagre
- Akkumuleringstank værk
- El-markeder
- Driftsstrategi

Udskrifter

- Produktion, grafisk
- Produktion, carpet
- Energiomsætning, Årlig
- Energiomsætning, Månedlig
- Varighedskurve for varmebehov
- Miljø
- Likviditetsbudget
- Resultat af ordinær drift
- Økonomiske nøgletal
- Forudsætningskatalog, Teknik
- Forudsætningskatalog, Økonomi

Projekt identifikation (maksimalt 4 linier)
Hadsund Fjernvarmevark Masterplan (934)

Forudsætninger til visning i Forudsætningskataloget

Vælg beregningsmodul
Projektering

- DESIGN - beregner energiomsætning og driftsøkonomi for et specifikt år
- FINANCE - planlægning for flere år, incl. investering og finansiering
- ACCOUNTS - plus resultatopgørelser og skat

Optimering af daglig drift

- OPERATION - optimering af energiomsætningen for en kortere periode

Avanceret

- Leverance af både varme og procesvarme
- Opstart af produktionenheder er langsom og dyr
- Brændselsproducerende produktionenheder i projektet
- Tillad enheder drift i faste blokke

Vis advarsel ved behov ikke opfyldt


- Varme
- Procesvarme
- Koling
- Elektricitet

Længde på beregningsskridt: 1 Time Advarsel når tidsserier skifter asynton med beregningsskridt

Længden af optimeringsperioden: Måned (anbefalet) År

Check input data: Automatisk Kun for beregning

Udvid tidsserie udover planperioden før og efter planperioden med: 0 Dage



energyPRO - Input

Individualisierbares Modell, dank
Zeitreihen & Zeitreihe-Funktionen

Randbedingungen

Zeitreihe

- Udetemperatur, DRY, zone 3, Jyllands østkyst
- Samlet solindstråling, DRY, zone 1, Nordjylland
- Fremløbstemperatur 2014
- Returtemperatur 2014
- Temp Solfanger Frem
- Vindhastighed, DRY, zone 2, det centrale Jylland
- DK-Vest Spotpriser 2014
- El-effektV80
- El-effektV100
- VP Temp Varm

Varmepumpe vind 50%
Verbunden mit Standort: Hadsund Varmeværk inkl. VSV

Anlagentyp: Kessel Stillstandszeiten:

Brennstoff: Wind fra V100 Leistungseinheit: MW

Mindestlaufzeit (Stunden): 0

Leistungskurve

Betriebsdaten	Brennstoff	Wärme
MW	MW	
Linear $Pel(\cdot) = 0,25 \cdot (Pe(\cdot) \cdot COP(\cdot))^{0,25}$		

Zeitreihenfunktion


Symbol: COP
Einheit: COP
Funktion: $(TVPV(\cdot) + 273,15) / (TVPV(\cdot) - TG(\cdot))^{0,72}$

Werte in Umwandlungstabelle modifizieren


Betrieb von anderer Anlage abhängig

- Wirtschaftlichkeit**
- Betriebliche Einnahmen**
 - El-salg fra vind [V80]
 - Pristillæg vind [V80]
 - Pristillæg vind [fast] [V80]
 - El-salg fra vind [V100]
 - Pristillæg vind [V100]
 - Pristillæg vind [fast] [V100]
- Betriebliche Aufwendungen**
- Braendselsgifter**
 - Flisbrændsel Kedel 1
 - Flisbrændsel Kedel 2
 - Olie
 - Spotafregning VP net
- Afgifter + gebyrer**
- Flis**
 - NOx-afgift
- Olie**
 - Energiafgift
 - CO2-afgift
 - NOx-afgift
- VP-net**
 - Elafgift
 - PSO
 - Transport Energinet.dk
 - Transport Energimidt Net
- Drift & vedligehold**
 - Solfelt D&V
 - Fliskedel 1 D&V
 - Fliskedel 2 D&V
 - Oliedel 1 D&V
 - Oliedel 2 D&V
 - Oliedel 3 D&V
 - Oliedel 4 D&V
 - Oliedel 5 D&V
 - Vind-varmepumpe D&V
 - Vind-varmepumpe 2 D&V
 - Vind-varmepumpe 3 D&V
 - Net-varmepumpe D&V
 - Net-varmepumpe 2 D&V
 - Net-varmepumpe 3 D&V
 - Vindmølle [V80] D&V
 - Vindmølle [V100] D&V

energyPRO - Betriebsstrategie



energyPRO – Saisonale Betriebsunterschiede



Ergebnisse – Referenz

Selskabsøkonomi Del 0, Referencen		Del 0, Referencen Reference
Varmeproduktion ab værk	MWh/år	70.000
Driftsomkostninger	kr./år	11.413.000
Driftsomkostninger, inkl. kapitalomk. til nuv. solvarme	kr./år	13.441.000
Varmeproduktionspris	kr./MWh	192


Varmeproduktionsfordeling ab værk	Del 0, Reference	
	MWh/år	%
Fliskedler	60.246	85,8%
Oliekedler	3	0,0%
Solvarme	9.981	14,2%
Overskudsvarme	-	0,0%
Transmissionstab & evt. afblæsning	-230	
Varmepumpe		0,0%
Total	70.000	

Brændsels- og ressourceforbrug		Del 0, Reference
Flis	MWh/år	58.519
Olie	MWh/år	3
Flis	ton/år	20.962
Olie	ton/år	0

Ergebnisse – Solarthermie

Selskabsøkonomi Del 3, Grundberechnung	Teil 0, Referenz	Teil 3.1 Erweiterung Solarthermie + Trockenkühler	Teil 3.2 Erweiterung Solarthermie + erweiterter Wärmespeicher	Teil 3.3 Erw. Solarthermie + Abwärme Klärwerk	Teil 3.4 Erw. Solarthermie + Biogas-Abwärme
Wärmeerzeugung Ab Werk	MWh/a	70.000	70.000	70.000	70.000
Betriebskosten	€/a	1.538.000	1.423.000	1.420.000	1.423.000
Betriebskosten inkl. Annuität zur 2015-Solarthermie	€/a	1.811.000	1.697.000	1.693.000	1.696.000
Betriebsersparnis	€/a		115.000	118.000	115.000
Solarthermie, inkl. Wärmetauscher, Pumpen, Rohrführung etc.	€		2.255.000	2.255.000	2.255.000
Trockenkühler	€		44.000	-	44.000
Wärmespeicher	€		-	288.000	-
Anschluss, Abwärme	€		-	-	189.000
Projektierung & Aufsicht	€		61.000	61.000	71.000
Unvorhergesehene Kosten	€		101.000	101.000	121.000
Investition total	€		2.461.000	2.705.000	2.681.000
Simple Amortisation	Jahre		21,4	22,9	23,3
Annuität, 3%, 25 Jahre	€/a		141.000	155.000	154.000
Netto-Ersparnis	€/a		-27.000	-37.000	-39.000
Wärmegestehungskosten	€/MWh		24,2	24,2	24,2
Wärmegestehungskosten, inkl. Annuität	€/MWh	25,9	26,3	26,4	26,4
Netto-Ersparnis in den Wärmegestehungskosten	€/MWh		-0,4	-0,5	-0,6
					-0,8

Ergebnisse – Szenarienanalyse



Sensitivitätsanalysen

- Um die Robustheit der Konklusionen zu untersuchen
 - Keine der untersuchten Änderungen führt veränderte Konklusionen mit sich.
- Analysen:
 - Hackschnitzelpreis: +20%
 - Abschaffung der NO_x-Abgabe
 - Energieeinsparungen durch Solarthermie nach 2015
 - Berechnung des balancierenden Hackschnitzelpreises
 - Substitutionspreis für industrielle Abwärme
 - Bei Erdgas-KWK: Strom- und Erdgaspreis in mehreren Ausgaben

Konklusion

- Die größte Reduktion des Hackschnitzelverbrauchs bei Grundwasser-WP & WKA
 - Erweiterung Solarthermie reduziert um 1.600 t/a
- Betriebswirtschaftliche Vorteile nur bei Versorgung des Großverbrauchers & erhöhter Biogas-Lieferung
- Weitere Szenarien resultieren in Mehrkosten von etwa 11.500 – 40.400 €/Jahr, bei merkbarer Reduktion des Hackschnitzelverbrauchs
 - Max. 0,577 €/MWh = 13,05 €/Verbraucher (inkl. MWst.)

Workshops

Danish experiences in district heating on renewable energy sources



EKI-Fachforum, New Energy in Husum 18 March 2016




Co-funded by the Intelligent Energy Europe
Programme of the European Union

Morten Hofmeister & Max Guddat



SmartReFlex, workshops



The Steps in Planning of Heating Systems

- 1. Mapping of present and future heat and cooling demands**
- 2. Mapping of resources**
- 3. Cost and competitiveness. Where to have individual solutions and where to have common solutions (district heating and cooling)**



energyPRO

Simulation and optimisation of energy production hour by hour



Techno-economical analyses

- Operation budgets
- Operation optimisation
- Operation follow-up
- Investment analyses
- Market participation and simulation
- Analyses of connection of DH networks

Brochure


www.emd.dk

Tutorial

<http://www.emd.dk/files/energypro/Tutorials/The%20complete%20tutorial.html>



energy PRO



Danish experiences in district heating on renewable energy sources

energyPRO, modules

Accounts:

- Income statement
- Taxes, more detailed
- Feasibility on company level
(not yet socio-economic)

Operation:

- < 1 year

Regions:


- Several locations
- Transmission pipelines

Markets:

- Several electricity markets in the same model

Finance:

- Several years
- NPV
- Financing
- IRR (only greenfield)



Design:

- 1 year
- Operation budget
- Investment analyses

Export of data:

- As PDF files
- As data (e.g. to Excel)


energyPRO, user interface

The screenshot shows the energyPRO 4.3 user interface with several sections highlighted:


- Input:** A red circle highlights the "Input data" section on the left, which contains a tree view of project components: Project identification, External conditions, Sites, Transmissions, Fuels, Demands, Energy conversion units, Storages, Electricity markets, Operation strategy, Environment, and Economy.
- Output:** A red circle highlights the "Reports" section on the left, which contains a tree view of report types: Production, graphic; Production, carpets; Energy conversion, annual; Energy conversion, monthly; Environment; Cash Flow, monthly; Operation Income; Financial Key Figures; Catalogue of Technical Assumptions; Catalogue of Economic Assumptions; Operation Strategy Calculation; Graphical Layout; and Project Reports.
- Calculation Module:** A red box highlights the "Select calculation module" section on the right, which includes options for "Projecting" (DESIGN, FINANCE, ACCOUNTS) and "Optimizing daily operation" (OPERATION). There is also an "Advanced" checkbox.

energyPRO, output




- Production graphic



- Production carpets



- Duration curves; Operation time, input, productions



The screenshot shows the energyPRO 4.3 software interface. The menu bar includes File, energyPRO setup, Project setup, and Tools. The toolbar has icons for file operations like Open, Save, Print, and a calculator. The main window shows 'Input data' and 'Project identification'. A red circle highlights the 'Reports' section on the right, which lists various report types:

- Production, graphic
- Production, carpets
- Energy conversion, annual
- Energy conversion, monthly
- Energy conversion, summary
- Duration curve for heat demand
- Environment
- Cash Flow, monthly
- Cash Flow, summary
- Cash flow, graphic
- Financial Key Figures
- Income Statement
- Income Statement, summary
- Balance Sheet
- Balance Sheet, summary
- Catalogue of Technical Assumptions
- Catalogue of Economic Assumptions
- Operation Strategy Calculation
- Graphical Layout
- Project Reports

energyPRO, application context



Questionnaire, new district heating
Map of the city
Number of consumers, total
Consumption, total MWh/year
Expected connection to district heat, total MWh/year
Fuel prices delivered at the district heating plant for:
Straw
Wood chips
Wood pellets
Naturel Gas
Number of degree days (indoor temp. 17° C) monthly
Feed-in tariff for electricity
Price for 1 m ² field for solar collectors
Ground conditions (sand, gravel, clay, rock)
Financing costs
Ideas to future combination of fuels in DH production unit




- Technical and economical data
- Questionnaires
- Project budget



Co-funded by the Intelligent Energy Europe
Programme of the European Union

Spreadsheet

- Input from energyPRO energy conversion and operation economy
- Calculations on feasibility (consumer, company, society)
- Project period (e.g. 20-30 years)
- Environment (not in energyPRO)



	A	B	C	D	E	F
Selskabsøkonomi						
Investering	kr.	0	13.768.733	13.768.733		
Ønsket tilbagebetjeligtid	år	2.714.000	1.222.000	1.492.000		
Kapitalomkostninger, gnm.	kr./år	0	925.341	925.341		
Nettohedspariske	kr./år	-	-	566.659		
Forbrugerekonomi						
Personel af drift, jf. Bilag A	kr.	2.714.000	1.222.000	1.492.000		
Personel af drift, jf. Bilag B	kr.	0	13.768.733	-13.768.733		
Kapitalomkostninger, gnm.	kr./år	0	925.341	925.341		
Ønsket af drift inkl. kapitalomkostninger	kr./år	5.714.300	2.447.341	566.659		
Varmeproduktionspris inkl. kapitalomkostninger	kr./MWh	274	216	57		
Varmebetrieb, standardhus	kr.	1.77	18.1	-		
Varmebetrieb, standardhus "ab-usek"	kr.	28.03	25.03	-		
Moms	%	25%	25%	-		
Variable varmeudgifter inkl. moms, standardhus	kr./år	8.581	6.774	1.788		

	A	B	C	D	E
Forskriftsgrundlag for teknologiske udviklinger i energipolitikken					
Energiudvalget, december 2014. Samt tilhørende jen/2010.					
Værk:					
Projekt:					
Samfundsekonomi	REFERENCE	2014-år	STANDARD	2014-år	STANDARD
Interest rate					
Energiudvalgning					
Grundlag:					
Ønsket af drift inkl. kapitalomkostninger	kr./år	5.714.300	2.447.341		
Brændstof	kr./MWh	441	441	REFERENCE!	REFERENCE!
Brændevar	kr./MWh	6.211	6.277	REFERENCE!	REFERENCE!
Økonomisk tilskud	kr./MWh	274	216	57	57
Effektiv pris	kr./MWh				
Premiepris	kr./MWh	2044,40			
Kalkulatoriske rater	kr./MWh	4,08%			
Glossari					
Ønsket af drift inkl. kapitalomkostninger	kr./år	76.239	64.022		
Økonomisk tilskud	kr./år	2.192.441	1.673.942		
Referencer					
Ønsket af drift inkl. kapitalomkostninger					
Ønsket af drift inkl. kapitalomkostninger	kr./år	52.417.333			
Ønsket af drift inkl. kapitalomkostninger	kr./år	42.466	620.464		
Ønsket af drift inkl. kapitalomkostninger	kr./år			-850.494	
Areal driftsfor					
Ønsket af drift inkl. kapitalomkostninger					
Ønsket af drift inkl. kapitalomkostninger	kr./år	30.0			

SmartReFlex Workshops



4th International
Solar District Heating
Conference
21-22 September 2016, Billund, Denmark



www.solar-district-heating.eu

The fourth edition of the International Solar District Heating Conference will take place on 21 and 22 September 2016 in Europe's No.1 SDH market in Denmark.

More information on:

www.planenergi.dk

www.solar-district-heating.eu

www.smartreflex.eu

Morten Hofmeister, mh@planenergi.dk, 0045 2234 4703

Max Guddat, mgag@planenergi.dk, 0045 2386 2482